

**Village of Convoy
Drinking Water Consumer Confidence
Report for 2023**

The Village of Convoy Water Department has prepared the following report to provide information to you, the consumer, on the quality of our drinking water as required by the Ohio Environmental Protection Agency. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts. The village has a current unconditional license to operate.

The Village of Convoy receives its drinking water from three drilled wells one on Elm Street and two on Industrial Drive.

What are sources of contamination to drinking water?

The sources of drinking water both tap water and bottled water includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbiological contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water.

The EPA requires regular sampling to ensure drinking water safety. In 2023 the Village of Convoy conducted sampling for many contaminants. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some contaminants are monitored for more than once per year such as bacteria, which is monitored twice per month in the distribution system. Listed in the table on the back, are contaminants that were found in the Village of Convoy's drinking water. Note that none of the contaminants exceeded the **Maximum Contaminant Level (MCL)** that is set by the EPA.

The Village is required to monitor your drinking water for specific contaminates on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 3rd quarter of 2023, we did not monitor for the following contaminants and therefore cannot be sure of quality of water during that time: GROSS ALPHA AND RADIUM 228. Health effects for people who drink water with excess amount of Alpha emitters and radium 226 or 228 above the MCL over many years may have a increased chance of getting cancer. The Village was back in compliance during the fourth Quarter of 2023 by collecting the sample for radiological. Steps have been taking to ensure that all sampling will be conducted as required by enacting a more comprehensive management plan.

While your drinking water meets Ohio EPA standards for arsenic, it does contain low levels of arsenic. EPA'S standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Lead Educational Informational

If Present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Convoy is responsible for providing a high quality of drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

How do I participate in decisions concerning my drinking water?

Public participation and comment are encouraged at regular meetings of the Board of Public Affairs which meets, , January 29, 2024, February 26, 2024, March 26, 2024, April 30, 2024, May 28, 2024, June 25, 2024, July 30, 2024, August 27, 2024, September 24, 2024, October 29, 2024, November 26, 2024, December 31, 2024, and January 28, 2025.

For more information on your drinking water contact Terry Crowle, Water/Wastewater Superintendent, at 419-749-2923.

Definitions of some terms contained within this report.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days, or one ounce of water in 7350 gallons of water,

Parts per Billion (ppb) or Micrograms per Liter (µg/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years, or one ounce of water in 7,350,000 gallons of water.

Maximum Residual Disinfectant Level Goal (MRDLG):the level of drinking water disinfectant, below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

The “<<symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.

Action Level (AL) Concentration: of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Picocuries per liter (pCi/l) – Is a unit of measurement for radiation absorption by the body.

Listed on the back is information on those contaminants that were found in the Village of Convoy's drinking water.

Ohio EPA in cooperation with the Convoy Water Department, recently completed a study of Convoy's source of drinking water, to identify potential contaminant sources and provide guidance on protecting the drinking water source. According to this study, the aquifer (water-rich zone) that supplies water to Convoy has a low susceptibility to contamination. A source water assessment may be found at Village of Convoy WWTP contact Terry Crowle 419-749-2923. This determination is based on the following:

- Presence of a thick protective layer of low permeable material overlying the aquifer,
- Significant depth (28-36 feet below ground surface of the aquifer,
- No evidence to suggest that ground water has been impacted by any significant levels of chemical contaminants from human activity.
- No apparent significant potential contaminant sources in the protection area.

TABLE OF DETECTED CONTAMINANTS

Contaminants (Units)	MCLG	MCL	EP001 Level Found	EP001 Range of Detections (Year)	EP002 Level Found	EP002 Range of Detections (Year)	EP003 Level found	EP003 Range of Detections	Sample Year	Violation	Typical Source of Contaminants
Radioactive Contaminants											
Gross alpha (pCi/L)	0	15	4.44	NA (2019)	13.1	4.17-13.1 (2023)	4.26	NA (2019)	See Range	yes	Erosion of natural deposits.
Combined Radium 226 228	0	5			1.88	1.00-1.88 (2023)				yes	Erosion of natural deposits.
Inorganic Contaminants											
Barium (ppm)	2	2	0.018	NA	0.016	NA	0.016	NA	2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride (ppm)	4	4.0	1.11	NA	1.14	NA	1.09	NA	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Arsenic (ppb)	0	10	4	NA	ND	NA	4	NA	2022	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Disinfectant and Disinfectant By-Products (Distribution Sampling)										Definitions	
Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Year Sampled	Typical Source of Contaminants		<ul style="list-style-type: none"> • Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. • Maximum Contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. • Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. • Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. • Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. • Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days. 		
Chlorine (ppm)	MRDLG= 4	MRDL= 4	1.38	0.8 to 1.9	No	2023	Water additive used to control microbes				
Haloacetic Acid (Haa5) ppb	NA	60	14.9	10 to 14.9	No	2023	By product of drinking water disinfection				
Total Trihalomethanes (TTHM) (ppb)	NA	80	71.2	46.2 to 71.2	No	2023	By-products of drinking water disinfection				
Lead and Copper											
Contaminants (units)	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Violation	Year Sampled	Typical source of Contaminants					
Lead (ppb)	15 ppb	NA	0	No	2023	Corrosion of household plumbing systems; Erosion of natural deposits.					
0 out of 10 samples were found to have lead levels in excess of the lead action level of 15 ppb.											

Copper (ppm)	1.3 ppm	NA	0.43	No	2023	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.	• Parts per Billion (ppb) or Micrograms per Liter (µg/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.
0 out of 10 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.							

DRINKING WATER NOTICE

Monitoring requirements not met for CONVOY VILLAGE

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the Third Quarter of 2023 time period we did not monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time: GROSS ALPHA AND RADIUM - 228.

What Should I Do?

This notice is to inform you that CONVOY VILLAGE did not monitor and report results for the presence of the contaminants listed above in the public drinking water system during the Third Quarter of 2023 time period, as required by the Ohio Environmental Protection Agency. You do not need to take any actions in response to this notice.

What Is Being Done?

Upon being notified of this violation, the water supply was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

A sample was (will be) collected on 10-25-23.

Sample results and additional information may be obtained by contacting CONVOY VILLAGE at:

Contact Person: Terry Crowle

Phone Number: 419-203-4465

Mailing Address: PO BOX 310 CONVOY OH 45832

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH8100112 Facility ID: 8160620

Date Distributed: _____